

Display energy certificate (DEC)



The Old Mining College Queen Street BURNTWOOD WS7 4QH	Operational rating <h1>E</h1>	Certificate number: 0720-0517-7539-5892-0092
		Valid until: 30 January 2024
		Total useful floor area: 665 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D		
101-125	E	102 E	100
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
January 2014	102 E
January 2013	110 E

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
January 2014	17	40	N/A
January 2013	21	42	N/A

Assessment details

Assessor's name	Stephen Ashton
Employer/Trading name	Information Prophets Ltd
Employer/Trading address	Unit 10 Enterprise House, Manchester Science Park, Lloyd Street North, M15 4SE
Assessor's declaration	Not related to the occupier.
Accreditation scheme	CIBSE Certification Limited
Issue date	13 December 2013
Nominated date	31 January 2014

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	47	313
Typical energy use (kWh/m ² /year)	108	134
Energy from renewables	0%	0%